

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:15 pm

PWS ID: UTAH16008 **Name:** OTTER CREEK LAKE BEACH
Legal Contact: UTAH STATE PARKS SOUTHWEST REG **Rating:** Approved
 LARRY D GRAY **Rating Date:** 11/17/2004
Address: 585 N MAIN **Activity Status:** Active
 CEDAR CITY, UT 84721
Phone Number: 435-586-4497
City Served (Area):
County: PIUTE COUNTY
System Type: Non-community **Last Inv Update:** 08/01/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 12/15/2010 **Total Dsgn Cap:**
Population: 26 **Surveyor:** JOHN VERCOE **Total Emerg Cap:**
Oper Period: 1/1 to 12/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office Phone Numbers	Emergency	Email Address
AC	GRAY, LARRY D	SW REGION M/	435-586-4497		larrygray@utah.gov

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	9
			9 Total Svc Connections

Storage

Total Storage: 40,000 GAL **Number of Units:** 2 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST002	FIBERGLASS TANK	Reservoir	20,000			A	
ST001	STEEL TANK	Ground	20,000 GAL	Steel		A	NO

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	OTTER CREEK BOOSTER	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	OTTER CREEK WELL	Active	WL	2			Yes	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.